

Confirmation

LEED

On 13 November 2015, Eurofins Product Testing A/S received a sample of a Construction adhesive with the product name:

VMH / Liquid Roc 200

supplied by

Metall-Kunststoff-Technik GmbH & Co. KG

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, ISO 11890-1 and ASTM D2369 and EPA method 24 testing standards (See test report no. 392-2015-00366601_H_EN_07 and 392-2015-00357601_12).

The test results of the tested coating indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions and VOC content by complying with:



VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in both office and class room.

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of SCAQMD rule 1168 (2005)

14 March 2018


Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry
Thomas Bjerring
Analytical Service Manager